

# Annexure C

## PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 101/2024

Dated: 24.09.2024

It is certified that an inspection team headed by CHANDNI RAIS P.A to Chairman

(Name of Officers with designation) from MUNICIPALITY SEOHARA PHED

inspected the MARY AND JESUS CONVENT SCHOOL, MANDORI, SEOHARA

(Name & Address of the school) on 24.09.2024 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. HTRC/2024/09/23/02 dated 23.09.2024

of HI-TECH TESTING & RESEARCH CENTER LUCKNOW (PHED Lab) certified that

the MARY AND JESUS CONVENT SCHOOL (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till 23.09.2026

Signature with Seal

Name

Designation

Name & Address of the Office / Department :

फैसल वारसी  
अध्यक्ष  
नगर पालिका परिषद  
सोहरा (बिजनौर)

FAISAL WARSI

CHAIRMAN, SEOHARA

MUNICIPAL OFFICE, SEOHARA

To MARY AND JESUS CONVENT SCHOOL

MANDORI SEOHARA, BIJNOR

(Name & Address of the Institution) U.P.

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

Executive Engineer  
P.H.E.D. Bijnor



# HI-TECH TESTING & RESEARCH CENTER

A strong foundation for tomorrow—

ISO 9001: 2015 CERTIFIED AND NABL ACCREDITED LABORATORY  
BUILDING MATERIAL, ROAD MATERIAL & SOIL, INDUSTRIAL TESTING LAB

Test Report No. HTRC/2024/09/23/02

## TEST REPORT

Dispatch Date: 23.09.2024

1	Name and Address of Customer	Mary & Jesus Convent School Mandori Seohara District- Bijnor (U.P.) - 246746
2	Type of Material Tested	Drinking Water
3	Water Condition	Normal
4	Date of Receipt of Sample	19.09.2024
5	Date of Laboratory Testing	19.09.2024 to 23.09.2024
6	Specification Code / Test Protocol	IS:10500, IS 456-2000, Test Method - IS 3025
7	Environmental Conditions	As Per Relevant Indian Standard

### TEST RESULTS

#### Drinking Water

Sr.No	Parameter	Test Method	Result	Units	Acceptable Limit	Permissible Limit in the absence of alternate source
1	PH VALUE	IS:3025(Part-11)	7.09	-	6.5-8.5	-
2	COLOUR	IS:3025(Part-4)	<5.0	Hazen	4	20
3	ODOUR	IS:3025(Part-5)	Agreeable	-	-	-
4	TASTE	IS:3025(Part-8)	Agreeable	-	-	-
5	TURBIDITY	IS:3025(Part-10)	<1.0	NTU	1	10
6	TOTAL HARDNES (as CaCO <sub>3</sub> )	IS:3025(Part-21)	30.2	Mg/l	200	600
7	CHLORIDE (as Cl)	IS:3025(Part-32)	22.09	Mg/l	250	1000
8	RESIDUAL FREE CHLORINE	IS:3025(Part-26)	<0.1	Mg/l	0.2max	-
9	IRON (as Fe)	IS:3025(Part-52)	<0.01	Mg/l	0.2max	-
10	FLUORIDE (as F)	IS:3025(Part-60)	<0.1	Mg/l	1	1.5
11	TOTAL DISSOLVED SOLID(TDS)	IS:3025(Part-16)	142	Mg/l	500	2000
12	TOTAL COLIFORM	IS:1622	Absent	MPN/100 MI	Absent	Absent
13	E. COLI	IS:1622	Absent	MPN/100 MI	Absent	Absent
14	CALCIUM	IS:3025(Part-40)	49.12	Mg/l	75 max.	200max.
15	MAGNESIUM	IS:3025(Part-46)	22.1	Mg/l	30 max.	-



htcindia@gmail.com  
lab@htcindia.co.in  
www.htcindia.co.in



HEAD OFFICE : SWAROOP NAGAR, NEAR DURGA TEMPLE LAKHIMPUR KHIRI, 262701  
CORP. OFFICE : VIVEKANANDPURI COLONY, NEAR AMOLI LAWN CHHATTHAMEEL  
RAITHA ROAD, LUCKNOW, 226201



05872-359265  
+91-9044999571  
+91-9044999572

● CHEMICAL

● MECHANICAL

● NDT

● GEOTECHNICAL

● CALIBRATION



# HI-TECH TESTING & RESEARCH CENTER

A strong foundation for tomorrow—

ISO 9001: 2015 CERTIFIED AND NABL ACCREDITED LABORATORY  
BUILDING MATERIAL, ROAD MATERIAL & SOIL, INDUSTRIAL TESTING LAB

**REMARKS: TEST RESULTS** Based on above tested parameter water sample meet as per IS-10500, IS 456-2000, Test Method – IS 3025 in Acceptable limit and water is fit for drinking purpose.

**\*\*End of the Report\*\***

- Environment conditions during the test were as per relevant IS standards.
- The test procedure performed as per IS-10500, IS 456-2000, Test Method – IS 3025

**PLEASE NOTE: -**

1. The result is of the sample as supplied by the customer.
2. The sample will be preserved in our laboratory for 15 days only from the date of issue of this test report.
3. This report is not valid for legal proceedings or Production in the Court of Law.
4. This report should not be treated as the endorsement of the sample submitted for testing.
5. This test report shall not be reproduced, except in full, without the written approval of this laboratory.
6. For any clarification, please correspond within 15 days of the issue of this test report.
7. Please fill up the enclosed customer feedback form and mail it to us.

Checked by



Authorized Signatory



htcindia@gmail.com  
lab@htcindia.co.in  
www.htcindia.co.in



HEAD OFFICE : SWAROOP NAGAR, NEAR DURGA TEMPLE LAKHIMPUR KHIRI, 262701  
CORP. OFFICE : VIVEKANANDPURI COLONY, NEAR AMOLI LAWN CHHATTHAMEEL  
RAITHA ROAD, LUCKNOW, 226201



05872-359265  
+91-9044999571  
+91-9044999572

● CHEMICAL

● MECHANICAL

● NDT

● GEOTECHNICAL

● CALIBRATION